

**RESOLUTION
BOARD OF COUNTY COMMISSIONERS
SITTING AS THE BOARD OF HEALTH
OURAY COUNTY**

Re: Ouray Mountain Rescue Team Sewer Connection Variance

WHEREAS, the Board of Health of Ouray County, Colorado, met in regular session on January 9, 2006; and

WHEREAS, the Ouray Mountain Rescue Team has submitted to Ouray County an application for a Variance to allow the use of a temporary septic holding tank in lieu of a required sewer connection for a public service facility located on CR 361; and

WHEREAS, the Board of Health has reviewed the request in accordance with Section 19.7 of the Ouray County Land Use Code and is ready to take action.

NOW, THEREFORE, BE IT RESOLVED, that in accordance with Section 19.7 of the Ouray County Land Use Code and by reason of an extraordinary and exceptional condition that exists that will result in undue hardship upon the owner of the property if the strict application of the regulations is observed, the Board of Health does hereby **APPROVE** the request with the following stipulations:

1. A septic holding tank maintenance schedule prepared by a civil engineer licensed in the State of Colorado shall be submitted to the Land Use Office for review and approval prior to the issuance of a Certificate of Occupancy for the proposed facility.
2. The final permanent sewer connection shall be made within 60 days of the completion of a city sewer line to the subject property.

Adopted this ____ day of _____, 2006.

BOARD OF HEALTH
OF OURAY COUNTY, COLORADO

ATTEST:

Heidi M. Albritton, Chair

Michelle Nauer, Clerk and Recorder

Don Batchelder, Vice Chair

By:

Linda Munson-Haley,
Deputy Clerk of the Board

Kristi R. Westfall, Member